Valve Regulated Lead Acid (VRLA) battery is specially designed for frequent cyclic discharge. By using strong grids and specially designed active material, the battery offers long cyclic life. It is applied in solar energy system, telecom, emergency lighting, UPS, marine, etc.

Specification

6 Cells per Unit

Voltage per Unit 12V

Capacity 150Ah@10hr-rate to 1.80V per cell @25°C Weight Approx. 35.0 KGS (Tolerance \pm 1.8%)

1000A (5 sec) Max. Discharging Current Approx. $3.5 \text{ m}\Omega$ **Internal Resistance**

Discharge: - 40°C - 50°C **Operating Temperature Range** Charge: 0°C - 50°C

25°C ± 5°C **Normal Operating Temperature Range**

13.6 - 14.4 VDC/unit average @ 25°C Float Charging Voltage

Recommended Maximum Charging Current

Equalization and Cycle Service Self Discharge

The battery can be stored for more than 6 months at 25°C. Self-discharge ratio less 3% per month at 25°C. Please charge battery before using.

14.6 - 14.8 VDC/unit average @ 25°C

Terminal F14

Storage: - 40°C - 50°C

ABS Container Material









Dimensions

Terminal









Constant Current Discharge Characteristics: A (25°C)

F.V/Time	5MIN	10MIN	15MIN	30MIN	1HR	2HR	3HR	4HR	5HR	8HR	10HR	20HR
9.60V	740.5	554.7	448.1	261.2	162.3	100.2	68.09	54.90	45.58	30.02	27.06	14.32
10.0V	719.1	527.8	438.9	257.9	160.1	98.18	66.83	54.12	45.17	29.90	26.79	14.06
10.2V	697.8	509.2	432.0	253.9	158.6	97.14	66.24	53.58	44.87	29.63	26.53	13.79
10.5V	626.6	469.9	411.3	246.9	156.7	95.87	65.65	52.79	44.50	29.37	26.26	13.52
10.8V	565.6	428.5	379.2	238.8	154.5	95.08	64.88	50.98	44.28	29.25	26.02	13.38
11.1V	482.9	382.9	340.1	229.7	150.8	91.25	63.61	50.25	43.96	29.01	25.72	12.84

Constant Power Discharge Characteristics: W (25°C)

F.V/Time	5MIN	10MIN	15MIN	30MIN	1HR	2HR	3HR	4HR	5HR	8HR	10HR	20HR
9.60V	7660	5908	4929	2990	1881	1174	802	657.2	546.0	359.5	324.4	172.5
10.0V	7509	5727	4850	2959	1863	1160	790	647.9	541.1	358.1	321.9	169.5
10.2V	7423	5576	4795	2934	1852	1152	786	641.9	537.8	355.4	319.0	166.4
10.5V	6758	5192	4574	2874	1841	1137	780	633.2	533.5	352.4	315.9	163.3
10.8V	6155	4786	4228	2806	1817	1129	771	611.8	531.1	350.9	312.8	161.7
11.1V	5406	4327	3806	2729	1790	1086	758	603.1	529.1	348.4	309.4	155.9


All mentioned values are average values Garnde Solar Energy Corp.


(Tolerance $\pm 2\%$).


1377 Jianlan Road, Ningbo, Zhejiang Province, China


VRLA Battery











Capacity Factors With Different Temperature

Battery	Туре	-20℃	-10°C	0℃	5℃	10℃	20℃	25℃	30℃	40℃	45°C
GEL	6V&12V	50%	70%	83%	85%	90%	98%	100%	102%	104%	105%
Battery	2V	60%	75%	85%	88%	92%	99%	100%	103%	105%	106%
AGM Battery	6V&12V	46%	66%	76%	83%	90%	98%	100%	103%	107%	109%
	2V	55%	70%	80%	85%	92%	99%	100%	104%	108%	110%

Discharge Current VS. Discharge Voltage

Final Discharge Voltage V/cell	1.75V	1.70V	1.60V	
Discharge Current (A)	(A) ≤0.2C	0.2C< (A) <1.0C	(A) ≥1.0C	

Charge the batteries at least once every six months, if they are stored at 25°C.

Charging Method:

Constant Voltage	-0.2Cx2h+14.4-14.7Vx24h,Max. Current 0.3C
Constant Current	-0.2Cx2h+0.1Cx7h+0.05Cx4h
Fast	-0.2Cx2h+0.3Cx3h

Bolt	M5	M6	M8
Terminal	F3 F4 F13 F18 T25 T26	F8 F11 F12-1 F15	F5 F9 F10 F12 F14 F16
Torque	6~7N-m	8~10N-m	10 [~] 12N−m

Maintenance & Cautions

Cycle	service
※ Avoid	battery over discharge, especially battery sereis connection use.
Charg	ed with recommend voltage, ensure battery can be full recharged.
In ger	neral, recharge capacity should be 1.1-1.15 times discharge capacity
※ Effect	of temperature on cycle charge voltage: -4mV/°C/Cell.
※ There	are a number of factors that will affect the length of cyclic service.
The m	ost significant are depth of discharge, ambient temperature,
discha	rge rate, and the manner in which the battery is recharged.
Gener	ally specking, the most important factors is depth of discharge.